

Best protection against electromagnetic interference is achieved by connection of the cable screens to PE.

For special cases with longer cables and small differences in earth potential between RHM and RHE installation the screens can be connected to PE_C. In case of substantial potential differences a potential equalization cable is mandatory.



When connecting the sensor and transmitter the respective local code for electrical installations must be considered.

Do not change the installation under power.

created / revised	
Date	17.11.2022
Drawn	H.G.Rudolph
Appr.	M. Weber



Wiring diagram RHE 46	
RHE46-RB**-**EB-***-	

Project	
Customer	
Draw Rev.	E46W-E_RB_EB_Rev_1_0
Sheet	1/1